



COUNTY OF IMPERIAL

DEPARTMENT OF PUBLIC WORKS

155 S. 11th Street
El Centro, CA
92243

Tel: (442) 265-1818
Fax: (442) 265-1858

Follow Us:



www.facebook.com/ImperialCountyDPW/



<https://twitter.com/CountyDpw/>



Public Works works for the Public

COUNTY OF IMPERIAL PUBLIC WORKS

155 S. 11th Street
El Centro, CA 92243


ARCHITECTURAL/MEP ENGINEERING DESIGN SERVICES COUNTY OF IMPERIAL PUBLIC HEALTH LAB REPLACEMENT OF 10 TON OSA AIR CONDITIONER PROJECT LOCATED AT 935 BROADWAY, EL CENTRO, CA – COUNTY PROJECT NO. SR6983HTH

ADDENDUM NO. 1

June 22, 2022

This *ADDENDUM* is hereby made part of the Contract Documents and specifications to the same extent as if originally included therein, and shall be signed by the Consultant and included with the proposal.

1. **Question:** Are previous design or as-built documents available for the facility?
Response: Original plans and other documents will be available to the selected consultant.
2. **Question:** Will there be any remodel of the space, or will it strictly be a unit replacement?
Response: The project is limited to the impacted unit and necessary components to replace and/or upgrade it with a code compliant system.
3. **Question:** What equipment or spaces are served by the unit?
Response: The impacted area is a Bio Safety Lab II.
The following equipment is within this room:
 - Biological safety cabinet(s)
 - Incubators (3 total) which are temperature sensitive.
4. **Question:** Will any equipment be added or removed from within the space?
Response: No.
5. **Question:** Are there specific State/Federal guidelines/standards/licensing the facility must meet?
Response: Not applicable to this project.
6. **Question:** Will the consultant be required to have a DIR number prior to submittal?
Response: All consultants are required to be registered with the Department of Industrial Relations at the time proposals are due and must submit proof of registration with the proposal.


John A. Gay, P.E.

Addendum No. 1
Page 1 of 2

Director of Public Works

Acknowledgement of Addendum No. 1

The general consultant is responsible for advising any and all subconsultants of this change. Each Consultant must acknowledge receipt of this addendum in the noted space below and where indicated on the Consultant's Proposal Section of the Special Provisions. This Addendum must be attached to the proposal.

License No: _____

Print or Type Company Name: _____

Print or Type Authorized Name: _____

Authorized Signature of Consultant:

Date Signed:
