



COUNTY OF IMPERIAL

DEPARTMENT OF PUBLIC WORKS

155 S. 11th Street
El Centro, CA
92243

Tel: (442) 265-1818
Fax: (442) 265-1858

Follow Us:



www.facebook.com/ImperialCountyDPW/



<https://twitter.com/CountyDpw/>



Public Works works for the Public

COUNTY OF IMPERIAL PUBLIC WORKS

155 S. 11th Street
El Centro, CA 92243

Imperial County North County Administration/Courthouse HVAC Replacement

220 Main Street, Brawley, Ca. 92227

County Project No. SR6650CFM

ADDENDUM NO. 4

OCTOBER 10, 2022

This *ADDENDUM* is hereby made part of the Contract Documents and specifications to the same extent as if originally included therein, and shall be signed by the Bidder and included with the proposal.

REVISION TO ADDENDUM NO. 3:

Item No. 1: Substitution Request.

The request is to provide HVAC equipment and product service, from DMG Corporation, for the subject project.

No.	Drawing/Spec. No.	Unit# Manufacturer Model#
1	M4.3	LG controls provided by DMG Service and Controls
2	M0.2	AHU-4: VTS Ventus AVS Custom air handler designed per plans, equipped with LG VRF AHU EEV and LG MultiV Communication
3	M0.2	CU 1A,B,C,2A,B,C: LG MultiV 5 VRF Unit System

Response No 1: (Revision)

a. LG shall be acceptable as an "or equal" for the VRF system & Controls, as will custom AHU manufacturer VTS America. Contractor shall be responsible for submitting shop drawings for all HVAC equipment coordinated with ductwork shop drawings to insure all proposed equipment aligns with all points of connections and space constraints. See specifications issued under Addendum 2.

B. "Equipment shown is specified at 460V, 3 phase. The available voltage at the facility is 208/120V, 3 phase. Please ensure equipment is specified at the available voltage."

John A. Gay, PE
Director of Public Works

Acknowledgement of Addendum No. 4 – Issued October 10, 2022

License No: _____

Print or Type Company Name: _____

Print or Type Authorized Name: _____

Authorized Signature of Contractor: _____

Date Signed: _____