



COUNTY OF IMPERIAL

DEPARTMENT OF PUBLIC WORKS

155 S. 11th Street  
El Centro, CA  
92243

Tel: (442) 265-1818  
Fax: (442) 265-1858

Follow Us:



[www.facebook.com/ImperialCountyDPW/](http://www.facebook.com/ImperialCountyDPW/)



<https://twitter.com/CountyDpw/>



Public Works works for the Public

COUNTY OF IMPERIAL PUBLIC WORKS

Various Roads Rehabilitation in Salton City; County Project No. 6940

**ADDENDUM NO. 2**

**January 11, 2024**

This *ADDENDUM* is hereby made part of the Contract Documents and specifications to the same extent as if originally included therein, and shall be signed by the Bidder and included with the proposal.

1. **Question:** "What are the working hours for the project?"

**Response:** Work hours shall be from 7:00 A.M. to 5:00 P.M. Alternative working hours may be authorized with a written approval by the Resident Engineer and County of Imperial Department of Public Works.

2. **Question:** "What is the Class II Aggregate Base thickness for the shoulder backing?"

**Response:** See Attached Exhibit "SALTON SEA VARIOUS ROADS PROJECT CLASS 2 BASE SHOULDER EXHIBIT"

John A. Gay, P.E.  
Director of Public Works

**Acknowledgement of Addendum No. 2**

The general contractor is responsible for advising any and all subcontractors of this change. Each bidder must acknowledge receipt of this addendum in the noted space below and where indicated on the Bidder's Proposal Section of the Special Provisions. This Addendum must be attached to the proposal.

License No: \_\_\_\_\_


Print or Type Company Name: \_\_\_\_\_

Print or Type Authorized Name: \_\_\_\_\_

Authorized Signature of Contractor: \_\_\_\_\_

Date Signed: \_\_\_\_\_

STREET IMPROVEMENTS  
PER PLANS



CONTRACTOR TO PLACE CLASS 2 BASE MATERIAL FLUSH WITH NEW A.C. PAVEMENT FOR A HORIZONTAL DISTANCE OF 4-FOOT OR AS ILLUSTRATED ON IMPROVEMENT PLANS BY THE HATCH AREA TO DAYLIGHT. COMPACT CLASS 2 BASE MATERIAL TO 95 PERCENT OF MAXIMUM DENSITY PER ASTM D-1557. APPLY LIGHT MIST OF WATER TO THE CLASS 2 SURFACE AFTER FINAL GRADING IS SATISFACTORILY COMPLETED.

CONTRACTOR TO CUT EXISTING NATIVE MATERIAL AS ILLUSTRATED.

EXISTING NATIVE MATERIAL TO REMAIN.

EXISTING NATIVE MATERIAL TO REMAIN.

REMOVE AND DISPOSE EXISTING NATIVE MATERIAL AND GRADE NATIVE SURFACE TO ACCOMMODATE 4-INCHES MINIMUM AT THE NEW EDGE OF PAVEMENT. GRADE SHOULDER TO A 5% MAX. SLOPE, FOR DISTANCE OF 4-FOOT. CLEAR AND GRUB DEBRIS AND VEGETATION.



**COUNTY OF IMPERIAL**  
DEPARTMENT OF PUBLIC WORKS  
EL CENTRO, CALIFORNIA

**SALTON SEA VARIOUS ROADS PROJECT  
CLASS 2 BASE SHOULDER EXHIBIT**

REVISIONS	BY:	APR'D:	DATE:	CHECKED:	DATE:
			/ /	VA	01/11/24
			/ /	AG	DWG No.: